

6.7.2 Culinary Water

A. In zones which require connection to a central water system:

1. Both “offsite” and “onsite” water mains sized per engineered design, as approved by the County, or as required by the serving entity shall be installed in such a way that each lot may be served therefrom.
2. Water service laterals shall be installed from the main line to at least six (6) feet inside the lot line. Said lateral shall include the installation of a meter box and meter setter.
3. The water flowing to said system shall be from a source and through lines which are sufficient in size to provide a volume of flow and level of pressure adequate for culinary use in accordance with State rules and County standards. In the absence of a specific standard, general engineering practices shall prevail.

B. In zones which allow utilization of individual cistern type systems:

The construction of the cistern shall be in accordance with Health Department rules and regulations. Completion, inspection, and approval by the Health Department shall be required as a condition of evidence of compliance with Health Department requirements.