

[Chapter 15.04 SUBDIVISIONS](#)

Section 15.04.530 Pipe.

All corrugated metal pipe shall be helically corrugated and shall conform to the requirements of the latest edition of AASHTO M-196 (aluminum alloy pipe) or AASHTO M-36 (galvanized pipe). Pipe shall be the size as shown on the drawings with a minimum of 16-gage or larger as determined by the County Flood Control Engineer. The minimum length of all pipes provided shall be twenty (20) feet, except where end sections, terminal sections, etc. require a shorter length of pipe. (Ord. 5-1988 § 1 (part): Development Code 4-3-2)